

EMC TEST REPORT

For

Mobile Power Bank

Model No : Lighthouse 2

Prepared for :
Address :

Prepared by : Shenzhen TCD Testing Technology Co.,LTD
Address : 6F,Liansheng Building,Gushu 1Rd,Xixiang Street,Baoan District
Shenzhen, Guangdong, China
Tel : (+86)755-29760321
Fax : (+86)755-29781725
Web : www.tcd-cert.com

Date of receipt of test sample : Feb 26, 2016
Number of tested samples : 1
Serial number : Prototype
Date of Test : Feb 26, 2016 - Mar 02, 2016
Date of Report : Mar 02, 2016

Note: This report shall not be reproduced except in full, without the written approval of Shenzhen TCD Testing Technology Co., Ltd. This document may be altered or revised by Shenzhen TCD Testing Technology Co., Ltd. personnel only, and shall be noted in the revision section of the document. The test results in the report only apply to the tested sample.

EMC TEST REPORT

EN 55022: 2010

Information technology equipment-Radio disturbance characteristics-Limits of measurement

EN 55024: 2010

Information technology equipment-Immunity characteristics-Limits and methods of measurement of measurement

Report Reference No' : TCD20160302103012E- 1

Date Of Issue..... : Mar 02, 2016

Testing Laboratory Name : Shenzhen TCD Testing Technology Co.,LTD

Address : 6F,Liansheng Building,Gsuhu 1st Road,Xixiang Street,Baoan District,Shenzhen,Guangdong,China

Testing Location/ Procedure : Full application of Harmonised standards ☒
Partial application of Harmonised standards ☐
Other standard testing method ☐

Applicant's Name..... :

Address :

Test Specification

Standard : EN 55022: 2010+AC:2011
EN 55024: 2010
EN 61000-3-2: 2014
EN 61000-3-3: 2013

Test Report Form No. : TCD20140719

TRF Originator..... Shenzhen TCD Testing Technology Co.,LTD

Master TRF Dated 2011-03

SHENZHEN TCD TESTING TECHNOLOGY CO.,LTD .All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the SHENZHEN TCD TESTING TECHNOLOGY CO.,LTD . is acknowledged as copyright owner and source of the material. SHENZHEN TCD TESTING TECHNOLOGY CO.,LTD takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

Test Item Description. : Mobile Power Bank

Trade Mark..... : xipin 希品

Model/ Type Reference..... : Lighthouse 2

Ratings : Input:5V/1A Output:5V/1A 5000mAh

Result : Positive

Compiled by:

Supervised by:

Approved by:

Jack Li

Rita Liu



Jake Li/ File administrators

Rite Liu/ Technique principal

Levis Li/ Manager

This report shall not be reproduced except in full, without the written approval of Shenzhen TCD Testing Technology Co.,Ltd.

EMC -- TEST REPORT

Test Report No. : TCD20160302103012E- 1

Mar 02, 2016

Date of issue

Type / Model..... : Lighthouse 2

EUT..... : Mobile Power Bank

Applicant..... :

Address..... :

Telephone..... : /

Fax..... : /

Manufacturer..... :

Address..... :

Telephone..... : /

Fax..... : /

Factory..... :

Address..... :

Telephone..... : /

Fax..... : /

Test Result according to the standards on page 6: **Positive**

The test report merely corresponds to the test sample.

It is not permitted to copy extracts of these test result without the written permission of the test laboratory.

TABLE OF CONTENT

Test Report Description	Page
1. SUMMARY OF STANDARDS AND RESULTS.....	6
1.1.Description of Standards and Results.....	6
1.2.Description of Performance Criteria	7
2. GENERAL INFORMATION.....	8
2.1.Description of Device (EUT)	8
2.2.Description of Test Facility	8
2.3.Statement of the measurement uncertainty.....	8
2.4.Measurement Uncertainty	9
3. measuring Devices and test equipment.....	10
3.1. Conducted Disturbance	10
3.2.Disturbance Power	10
3.3.Radiated Electromagnetic Disturbance	10
3.4.Radiated Disturbance (Electric Field)	10
3.5.Harmonic Current.....	10
3.6.Voltage fluctuation and Flicker	10
3.7.Electrostatic Discharge.....	10
3.8.RF Field Strength Susceptibility	11
3.9.Electrical Fast Transient/Burst	11
3.10.Surge	11
3.11.Conducted Susceptibility.....	11
3.12.Power Frequency Magnetic Field Susceptibility.....	11
3.13.Voltage Dips	11
3.14.Voltage Short Interruptions	11
4. RADIATED EMISSION MEASUREMENT.....	12
4.1.Block Diagram of Test Setup	12
4.2.Measuring Standard.....	12
4.3.Radiated Emission Limits	12
4.4.EUT Configuration on Test	13
4.5.Operating Condition of EUT	13
4.6.Test Procedure	13
4.7.Test Results	13
5. ELECTROSTATIC DISCHARGE IMMUNITY TEST.....	15
5.1.Block Diagram of Test Setup	15
5.2.Test Standard	15
5.3.Severity Levels and Performance Criterion	15
5.4.EUT Configuration on Test	15
5.5.Operating Condition of EUT.....	15
5.6.Test Procedure	16
5.7.Test Results	16
6. RF FIELD STRENGTH SUSCEPTIBILITY TEST.....	18
6.1.Block Diagram of Test	18
6.2.Test Standard	18
6.3.Severity Levels and Performance Criterion	18
6.4.EUT Configuration on Test	19
6.5.Operating Condition of EUT	19
6.6.Test Procedure	19
6.7.Test Results	19

7. MAGNETIC FIELD SUSCEPTIBILITY TEST	21
7.1.Block Diagram of Test Setup	21
7.2.Test Standard	21
7.3.Severity Levels and Performance Criterion	21
7.4.EUT Configuration on Test	21
8. EXTERNAL AND INTERNAL PHOTOS OF THE EUT	26

1. SUMMARY OF STANDARDS AND RESULTS

1.1. Description of Standards and Results

The EUT have been tested according to the applicable standards as referenced below.

EMISSION (EN 55022: 2010)			
Description of Test Item	Standard	Limits	Results
Conducted disturbance at mains terminals	EN 55022: 2010	Class B	PASS
Conducted disturbance at telecommunication port	EN 55022: 2010	Class B	PASS
Radiated disturbance	EN 55022: 2010	Class B	PASS
Harmonic current emissions	EN 61000-3-2: 2014	Class A	PASS
Voltage fluctuations & flicker	EN 61000-3-3: 2013	-----	PASS
IMMUNITY(EN 55024: 2010)			
Description of Test Item	Basic Standard	Performance Criteria	Results
Electrostatic discharge (ESD)	EN 61000-4-2: 2009	B	PASS
Radio-frequency, Continuous radiated disturbance	EN 61000-4-3: 2006+A1: 2008+A2: 2010	A	PASS
Electrical fast transient (EFT)	EN 61000-4-4: 2012	B	N/A
Surge (Input a.c. power ports)	EN 61000-4-5: 2014	B	N/A
Surge (Telecommunication ports)		B	N/A
Radio-frequency, Continuous conducted disturbance	EN 61000-4-6: 2014	A	N/A
Power frequency magnetic field	EN 61000-4-8: 2010	A	PASS
Voltage dips, >95% reduction	EN 61000-4-11: 2004	B	N/A
Voltage dips, 30% reduction		B	N/A
Voltage interruptions		C	N/A
N/A is an abbreviation for Not Applicable.			

1.2. Description of Performance Criteria

General Performance Criteria

Examples of functions defined by the manufacturer to be evaluated during testing include, but are not limited to, the following:

- essential operational modes and states;
- tests of all peripheral access (hard disks, floppy disks, printers, keyboard, mouse, etc.);
- quality of software execution;
- quality of data display and transmission;
- quality of speech transmission.

1.2.1. Performance criterion A

The equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacture when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the minimum performance level or the permissible performance loss is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.2. Performance criterion B

After the test, the equipment shall continue to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomena below a performance level specified by the manufacture, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.

During the test, degradation of performance is allowed. However, no change of operation state or stored data is allowed to persist after the test.

If the minimum performance level (or the permissible performance loss) is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.

1.2.3. Performance criterion C

Loss of function is allowed, provided the function is self-recoverable, or can be restored by the operation of the controls by the user in accordance with the manufacture's instructions.

Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.

2. GENERAL INFORMATION

2.1. Description of Device (EUT)

EUT	: Mobile Power Bank
Model Number	: Lighthouse 2
Power Supply	: Input:5V/1A Output:5V/1A 5000mAh
EUT Clock	: $\leq 108\text{MHz}$

2.2. Statement of the measurement uncertainty

The data and results referenced in this document are true and accurate. The reader is cautioned that there may be errors within the calibration limits of the equipment and facilities. The measurement uncertainty was calculated for all measurements listed in this test report acc. To CISPR 16 – 4 “Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC Measurements” and is documented in the TCD quality system acc. To DIN EN ISO/IEC 17025. Furthermore, component and process variability of devices similar to that tested may result in additional deviation. The manufacturer has the sole responsibility of continued compliance of the device.

2.4.Measurement Uncertainty

Test Item	Frequency Range	Expanded uncertainty (U _{lab})	Expanded uncertainty (U _{cispr})
Conducted Emission	(9kHz to 150kHz)	2.63 dB	4.0 dB
	(150kHz to 30MHz)	2.35 dB	3.6 dB
Power disturbance	(30MHz to 300MHz)	2.90dB	4.5 dB
Electromagnetic Radiated Emission (3-loop)	(9kHz to 30MHz)	3.60 dB	N/A
Radiated Emission	(9kHz to 30MHz)	3.68 dB	N/A
Radiated Emission	(30MHz to 1000MHz)	3.48 dB	5.2 dB
Radiated Emission	(above 1000MHz)	3.90 dB	N/A
Mains Harmonic	Voltage	0.510%	N/A
Voltage Fluctuations & Flicker	Voltage	0.510%	N/A

- (1) Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the apparatus.
- (2) The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor of $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.

3. MEASURING DEVICES AND TEST EQUIPMENT

3.1. Conducted Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2015/06/18
2	10dB Attenuator	SCHWARZBECK	OSPAM236	9729	2015/06/18
3	Artificial Mains	ROHDE & SCHWARZ	ENV216	101288	2015/06/18
4	EMI Test Software	AUDIX	E3	N/A	2015/06/18

3.2. Disturbance Power

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	101142	2015/06/18
2	Absorbing clamp	ROHDE & SCHWARZ	MDS 21	4033	2015/08/30
3	EMI Test Software	AUDIX	E3	N/A	2015/06/18

3.3. Radiated Electromagnetic Disturbance

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	EMI Test Receiver	ROHDE & SCHWARZ	ESCI	1011423	2015/06/18
2	Triple-loop Antenna	EVERFINE	LLA-2	11050003	2015/06/18
3	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2015/06/18
4	EMI Test Software	AUDIX	E3	N/A	2015/06/18

3.4. Radiated Disturbance (Electric Field)

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	3m Semi Anechoic Chamber	SIDT FRANKONIA	SAC-3M	03CH03-HY	2015/02/04
2	EMI Test Receiver	ROHDE & SCHWARZ	ESPI	101840	2015/06/18
3	Log per Antenna	SCHWARZBECK	VULB9163	9163-470	2015/06/18
4	EMI Test Software	AUDIX	E3	N/A	2015/06/18
5	Positioning Controller	MF	MF-7082	/	2015/06/18

3.5. Harmonic Current

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2015/06/18

3.6. Voltage fluctuation and Flicker

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power Analyzer Test System	Voltech	PM6000	20000670053	2015/06/18

3.7. Electrostatic Discharge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	ESD Simulator	KIKUSUI	KC001311	KES4021	2015/09/02

3.8.RF Field Strength Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	SIGNAL GENERATOR	HP	8648A	625U00573	2015/06/18
2	Amplifier	AR	500A100	17034	2015/06/18
3	Amplifier	AR	100W/1000M1	17028	2015/06/18
4	Isotropic Field Monitor	AR	FM2000	16829	2015/06/18
5	Isotropic Field Probe	AR	FP2000	16755	2015/06/18
6	Bi-conic Antenna	EMCO	3108	9507-2534	2015/06/18
7	By-log-periodic Antenna	AR	AT1080	16812	2015/06/18
8	EMS Test Software	ROHDE & SCHWARZ	ESK1	N/A	2015/06/18

3.9.Electrical Fast Transient/Burst

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Electrical fast transient(EFT)generator	3CTEST	EFT-4021	EC0461044	2015/01/20
2	Coupling Clamp	3CTEST	EFTC	EC0441098	2015/06/18

3.10.Surge

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Surge test system	3CTEST	SG5006G	EC5581070	2015/06/18
2	Coupling/decoupling network	3CTEST	SGN-5010G	CS5591033	2015/06/18

3.11.Conducted Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Simulator	EMTEST	CWS500C	0900-12	2015/06/18
2	CDN	EMTEST	CDN-M2	5100100100	2015/06/18
3	CDN	EMTEST	CDN-M3	0900-11	2015/06/18
4	CDN	EMTEST	CDN-M	0900-12	2015/06/18
5	Attenuator	EMTEST	ATT6	0010222A	2015/06/18
6	Infuse tongs	EMTEST	EM-Clamp	0513A031201	2015/06/18

3.12.Power Frequency Magnetic Field Susceptibility

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Power frequency mag-field generator System	EVERFINE	EMS61000-8K	906003	2015/06/18

3.13.Voltage Dips


Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2015/06/18

3.14.Voltage Short Interruptions

Item	Test Equipment	Manufacturer	Model No.	Serial No.	Last Cal.
1	Voltage dips and up generator	3CTEST	VDG-1105G	EC0171014	2015/06/18

4. RADIATED EMISSION MEASUREMENT

4.1. Block Diagram of Test Setup



4.2. Measuring Standard

EN 55022: 2010

4.3. Radiated Emission Limits

EN 55022 Limits:

All emanations from a class B device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified below:

FREQUENCY (MHz)	DISTANCE (Meters)	FIELD STRENGTHS LIMIT (dB μ V/m)
30 ~ 230	3	40
230 ~ 1000	3	47

Note: (1) The smaller limit shall apply at the combination point between two frequency bands.

(2) Distance refers to the distance in meters between the measuring instrument antenna and the closed point of any part of the EUT.

4.4.EUT Configuration on Test

The EN 55022 regulations test method must be used to find the maximum emission during radiated emission measurement.

4.5.Operating Condition of EUT

4.5.1 Turn on the power.

4.5.2 After that, let the EUT work in test mode (ON) and measure it.

4.6.Test Procedure

The EUT is placed on a turntable, which is 0.8 meter high above the ground. The turntable can rotate 360 degrees to determine the position of the maximum emission level. The EUT is set 3 meters away from the receiving antenna, which is mounted on a antenna tower. The antenna can be moved up and down from 1 to 4 meters to find out the maximum emission level. By-log antenna is used as a receiving antenna. Both horizontal and vertical polarization of the antenna is set on test.

The bandwidth of the Receiver is set at 120kHz.


The frequency range from 30MHz to 1000MHz is investigated.

4.7.Test Results

PASS.

The test result please refer to the next page.


Model No.	Lighthouse 2	Test Mode	ON
Environmental Conditions	24°C/ 56% RH	Detector Function	Quasi-peak
Pol	Vertical	Distance	3m
Test Engineer	jake Li		



	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	33.88	12.79	0.37	12.31	25.47	40.00	-14.53	QP
2	55.22	11.75	0.46	13.01	25.22	40.00	-14.78	QP
3	185.20	14.04	0.70	10.14	24.88	40.00	-15.12	QP
4	419.94	3.83	1.32	15.47	20.62	47.00	-26.38	QP
5	706.09	4.92	1.60	18.89	25.41	47.00	-21.59	QP
6	978.66	4.21	1.94	21.60	27.75	47.00	-19.25	QP

Note: 1. All readings are Quasi-peak values.
 2. Measured= Reading + Antenna Factor + Cable Loss
 3. The emission that ate 20db blow the official limit are not reported

Model No.	Lighthouse 2	Test Mode	ON
Environmental Conditions	24°C/ 56% RH	Detector Function	Quasi-peak
Pol	Horizontal	Distance	3m
Test Engineer	jake Li		




	Freq	Reading	CabLos	Antfac	Measured	Limit	Over	Remark
	MHz	dBuV	dB	dB/m	dBuV/m	dBuV/m	dB	
1	33.88	9.30	0.37	12.31	21.98	40.00	-18.02	QP
2	55.22	10.58	0.46	13.01	24.05	40.00	-15.95	QP
3	168.71	15.59	0.80	8.93	25.32	40.00	-14.68	QP
4	516.94	3.73	1.42	16.90	22.05	47.00	-24.95	QP
5	762.35	5.05	1.60	19.59	26.24	47.00	-20.76	QP
6	945.68	4.66	1.95	21.39	28.00	47.00	-19.00	QP

Note: 1. All readings are Quasi-peak values.
 2. Measured= Reading + Antenna Factor + Cable Loss
 3. The emission that ate 20db blow the official limit are not reported

5. ELECTROSTATIC DISCHARGE IMMUNITY TEST

5.1. Block Diagram of Test Setup



5.2. Test Standard

EN 55024: 2010

Severity Level: 3 / Air Discharge: $\pm 8\text{KV}$, Level: 2 / Contact Discharge: $\pm 4\text{KV}$)

5.3. Severity Levels and Performance Criterion

5.3.1. Severity level

Level	Test Voltage Contact Discharge (KV)	Test Voltage Air Discharge (KV)
1.	± 2	± 2
2.	± 4	± 4
3.	± 6	± 8
4.	± 8	± 15
X	Special	Special

5.3.2. Performance Criterion: **B**

5.4.EUT Configuration on Test

The configuration of EUT is listed in Section 2.1.

5.5.Operating Condition of EUT

Same as conducted emission measurement, which is listed in Section 4.5, Except the test set up replaced by Section 5.1.

5.6.Test Procedure

5.6.1.Air Discharge

This test is done on a non-conductive surface. The round discharge tip of the discharge electrode shall be approached as fast as possible to touch the EUT.

After each discharge, the discharge electrode shall be removed from the EUT. The generator is then re-triggered for a new single discharge and repeated 10 times for each pre-selected test point. This procedure shall be repeated until all the air discharge completed

5.6.2.Contact Discharge

All the procedure shall be same as Section 5.6.1. Except that the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.

5.6.3.Indirect Discharge For Horizontal Coupling Plane

At least 10 single discharges (in the most sensitive polarity) shall be applied at the front edge of each HCP opposite the center point of each unit (if applicable) of the EUT and 0.1m from the front of the EUT. The long axis of the discharge electrode shall be in the plane of the HCP and perpendicular to its front edge during the discharge.

5.6.4.Indirect Discharge For Vertical Coupling Plane

At least 10 single discharge (in the most sensitive polarity) shall be applied to the center of one vertical edge of the coupling plane. The coupling plane, of dimensions 0.5m X 0.5m, is placed parallel to, and positioned at a distance of 0.1m from the EUT. Discharges shall be applied to the coupling plane, with this plane in sufficient different positions that the four faces of the EUT are completely illuminated.

5.7.Test Results

PASS.

Please refer to the following pages

Electrostatic Discharger Test Results

Standard	<input type="checkbox"/> IEC 61000-4-2 <input checked="" type="checkbox"/> EN 61000-4-2		
Applicant			
EUT	Mobile Power Bank	Temperature	24℃
M/N	Lighthouse 2	Humidity	53%
Criterion	B	Pressure	1021mbar
Test Mode	ON	Test Engineer	jake Li

Air Discharge

Test Points	Test Levels			Results		
	± 2kV	± 4kV	± 8kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B

Contact Discharge

Test Points	Test Levels		Results		
	± 2 kV	±4 kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B

Discharge To Horizontal Coupling Plane


Side of EUT	Test Levels		Results		
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B

Discharge To Vertical Coupling Plane

Side of EUT	Test Levels		Results		
	± 2 kV	± 4 kV	Passed	Fail	Performance Criterion
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> A <input checked="" type="checkbox"/> B

6. RF FIELD STRENGTH SUSCEPTIBILITY TEST

6.1. Block Diagram of Test



6.2. Test Standard

EN 55024: 2010

(EN 61000-4-3: 2006+A1: 2008 Severity Level: 2, 3V / m)

6.3. Severity Levels and Performance Criterion

6.3.1. Severity Levels

Level	Field Strength (V/m)
1.	1
2.	3
3.	10
X.	Special

6.3.2. Performance Criterion: A

6.4.EUT Configuration on Test

The configuration of the EUT is same as Section 2.1.

6.5.Operating Condition of EUT

Same as radiated emission measurement, which is listed in Section 4.5, except the test setup replaced as Section 6.1.

6.6.Test Procedure

The EUT are placed on a table, which is 0.8 meter high above the ground. The EUT is set 3 meters away from the transmitting antenna, which is mounted on an antenna tower. Both horizontal and vertical polarization of the antenna is set on test. Each of the four sides of the EUT must be faced this transmitting antenna and measured individually. In order to judge the EUT performance, a CCD Recording is used to monitor its screen. All the scanning conditions are as following:

Condition of Test

Remark

- | | |
|---------------------------|-------------------------|
| 1. Fielded Strength | 3V/m (Severity Level 2) |
| 2. Radiated Signal | Unmodulated |
| 3. Scanning Frequency | 80-1000MHz |
| 4. Sweep time of radiated | 0.0015 Decade/s |
| 5. Dwell Time | 3 Sec. |

6.7.Test Results

PASS.

Please refer to the following page.

RF Field Strength Susceptibility Test Results

Standard	<input type="checkbox"/> IEC 61000-4-3 <input checked="" type="checkbox"/> EN 61000-4-3		
Applicant			
EUT	Mobile Power Bank	Temperature	24℃
M/N	Lighthouse 2	Humidity	53%
Field Strength	3 V/m	Criterion	A
Test Mode	ON	Test Engineer	jake Li
Frequency Range	80 MHz to 1000 MHz		
Modulation	<input type="checkbox"/> None <input type="checkbox"/> Pulse <input checked="" type="checkbox"/> AM 1KHz 80%		
Steps	1%		

	Horizontal	Vertical
Front	PASS	PASS
Right	PASS	PASS
Rear	PASS	PASS
Left	PASS	PASS


Test Equipment:

1. Signal Generator: 2031 (MARCONI)
2. Power Amplifier: 500A100 & 100W/1000M1 (A&R)
3. Power Antenna: 3108 (EMCO) & AT1080 (A&R)
4. Field Monitor: FM2000 (A&R)

Note:

7. MAGNETIC FIELD SUSCEPTIBILITY TEST

7.1. Block Diagram of Test Setup



7.2. Test Standard

EN 55024: 2010

(EN 61000-4-8: 2010, Severity Level: Level 1, 1A / m)

7.3. Severity Levels and Performance Criterion

7.3.1. Severity Levels

Level	Field Strength (A/m)
1	1
2	3
3	10
4	30
5	100
X	Special

7.3.2. Performance Criterion: A

7.4. EUT Configuration on Test

The configuration of the EUT is same as Section 2.1.

7.5.Test Procedure

The EUT is placed in the middle of a induction coil (1*1m), under which is a 1*1*0.1m (high) table, this small table is also placed on a larger table, 0.8 m above the ground. Both horizontal and vertical polarization of the induction coil is set on test, so that each side of the EUT is affected by the magnetic field. Also can reach the same aim by change the position of the EUT.

7.6.Test Results

PASS.

Please refer to the following page.

Magnetic Field Immunity Test Result

Standard	<input type="checkbox"/> IEC 61000-4-8 <input checked="" type="checkbox"/> EN 61000-4-8		
Applicant			
EUT	Mobile Power Bank	Temperature	24°C
M/N	Lighthouse 2	Humidity	53%
Test Mode	ON	Criterion	A
Test Engineer	jake Li		

Test Level (A/M)	Testing Duration	Coil Orientation	Criterion	Result
1	5 mins	X	A	PASS
1	5 mins	Y	A	PASS
1	5 mins	Z	A	PASS

Note:

8. EXTERNAL AND INTERNAL PHOTOS OF THE EUT



Fig 1



Fig 2



Fig 3



Fig 4

-----THE END OF REPORT-----